

Chesterfield County Codes Enforcement Office

County Annex Building
101 West Main Street #B
Chesterfield, SC 29709

Phone: (843) 623-9615
Fax: (843) 623-9637

Director
Keith Benton

Officers
David Wilks

MANUFACTURED HOUSING INSTALLATION GUIDELINES FOR THE UNINCORPORATED AREAS OF CHESTERFIELD COUNTY S.C.

The inspector will be inspecting the piers, tie downs, steps and landings, water and septic tank hook-up, and electric hook-up from the service pole to the manufactured home. The manufactured home must be inspected and approved by the Building Inspector prior to electrical hook-up from the electric company. A door must be unlocked or key available for inspection of inside sub-panel.

MANUFACTURED HOME SET-UP SHALL BE AS FOLLOWS:

It shall be unlawful for any person or legal entity to import any Pre-June 15, 1976 manufactured home into Chesterfield County.

Manufactured home must be registered within 15 days of moving home into Chesterfield County, and license decal must be posted in window.

SET-UP

Individual must be licensed by the Manufactured Housing Board in order to set-up a mobile home. The only licenses acceptable for the installation of manufactured homes are the *manufactured home contractor* and the *manufactured home installer* licenses.

All property line set-backs shall be satisfied:

PIERS

Piers shall be designed and constructed to distribute loads evenly. Multiple section homes may have concentrated roof loads which will require special consideration. Load-bearing piers may be constructed utilizing one of the methods below. Such piers shall be considered to resist only vertical forces acting in a downward direction. They shall not be considered as providing any resistance to horizontal loads induced by wind or earthquake forces.

- 1) A prefabricated load-bearing device that is listed and labeled for the intended use.

- 2) Mortar shall comply with ASTM C 270 Type M, S, or N; this may consist of one part Portland cement, one-half part hydrated lime and four parts sand by volume. Lime shall not be used with plastic or water proof cement.
- 3) A cast-in-place concrete pier with concrete having specified compressive strength at 28 days of 2,500 psi (17 225 kPa).

Alternate materials and methods of construction may be used for piers which have been designed by a design professional licensed by the state to practice as such.

Caps and leveling spacers may be used for leveling of the manufactured home. Spacing of piers shall be as specified in the manufacturer's installation instructions, if available or by an approved designer.

- 1) Except for corner piers, piers 36 inches or less in height may be constructed of masonry units, placed with cores or cells vertically. Piers shall be installed with their long dimension at right angles to the main frame member they support and shall have a cross-sectional area of 128 square inches. Piers shall be capped with minimum 4-inch solid masonry units or equivalent.
- 2) Piers between 36 and 80 inches in height and all corner piers over 24 inches in height shall be at least 16 inches by 16 inches consisting of interlocking masonry units and shall be fully capped with minimum 4-inch solid masonry units or equivalent.
- 3) Piers over 80 inches in height may be constructed in accordance with the provisions of item 2 above, provided the piers shall be filled solid with grout and reinforced with four continuous # 5 bars. One bar shall be placed in each corner cell of hollow masonry unit piers or in each corner of the grouted space of piers constructed of solid masonry units.
- 4) Cast in place concrete piers meeting the same size and height limitation of items 1, 2 and 3 above may be substituted for piers constructed of masonry units.

FOOTINGS

Footings are to be poured concrete at least 16"x16"x4" thick up to 48" high. Above 48" high footings shall be 16"x16"x6" thick and have an 8" wall with ties every 16" if brick skirting is used.

FRAME TIES

Only bolted or buckled ties are allowed. Anchoring equipment shall be so designed to prevent self-disconnection with NO HOOK ENDS PERMITTED .

	<u>Length up to 40'</u>	<u>41' to 60'</u>	<u>61' to 82'</u>
Frame ties per side (Diagonal Ties)	3	5	6
Over the roof ties	3	3	3
Total number of frame Ties per home	6	10	12

Note: Double Wides Do Not Require Over the Roof Tie Downs

Septic Tanks / Sewer Lines / Plumbing

Septic tanks shall be installed, approved by DHEC and hooked to the home prior to final inspection by the Building Inspector.

All sewer lines shall be scheduled 34, 50 or better. The lines should be properly fitted and glued and strapped up with approved strapping material. Any turn or drop greater than 45 degrees shall have a screw in type clean out installed upstream of the bend.

Outside Hose Bibs (spigot) must have backflow preventor installed unless approved antisiphonage faucet is installed.

SERVICE POLE / ELECTRICAL

Service pole installation per the utility company servicing your home. A diagram of proper installation can be obtained from your utility company. All services must comply with utility company standards. The service entrance cable to mobile homes shall be in approved conduit or be direct burial cable (DBC). If conduit is used, it must be buried a minimum of 12" deep. If (DBC) is used it must be buried 24" deep. All exposed cable (from service box to ground and from ground to mobile home) must be in conduit.

Aluminum service entrance cable must be 4/0 with 2/0 neutral (or larger). Copper must be 2/0 with 1/0 neutral (or larger).

Your utility company can supply you with a diagram for proper wiring specifications. Meter base must be located on a pole or pedestal and not attached to the structure.

Aluminum service conductors must have proper amount of approved compound or inhibitors applied to all end's at connection.

SMOKE DETECTORS

All manufactured homes shall have the required amount of operational located smoke detectors.

911 ADDRESS

The numbers shall be conspicuously placed immediately above, on or at the side of the property of each building so that the number can be seen clearly from the street line. Whenever the building is more than 50 feet from the street line or when the numbers at the door are not clearly visible from the street line, the number must be placed at the entrance to the building, on a mail box, gate post, fence or other appropriate place so as to be easily read from the street line.

Numbers shall not be less than three (3) inches in height, and shall be made of a durable and clearly visible material which is in contrasting color to the building.

LANDINGS AT DOORS

There shall be a floor or landing on each side of each exterior door.

EXCEPTION: Where a stairway of two or fewer risers is located on the exterior side of a door, Other than the required exit door, a landing is not required for the exterior side of the door.

The floor or landing at the interior side of the exit door required shall not be more than 1.5 inches lower than the top of the threshold.

EXCEPTION: The landing at an exterior doorway shall not be more than 7 3/4" below the top of the threshold, provided the door, other than an exterior storm or screen door does not swing over the landing.

The width of each landing shall not be less than the stairway or door served. Every landing shall have a minimum dimension of 36 inches measured in the direction of travel.

All Exit Doors shall be Max. 7 3/4" from threshold if door swings in. All exit doors shall be max. 1.5" from threshold if door swings out. Regardless if an exterior door (other than a storm or screen door) swings out - max. 1.5" from threshold.

GUARDS

Porches, balconies or raised floor surfaces located more than 30 inches above the floor or grade below, shall have guards not less than 36 inches in height. Open sides of stairs with a total rise of more than 30 inches above the floor or grade below, shall have guards not less than 30 inches and not more than 38 inches in height measured vertically from the nosing of the treads.

Required guards on open sides of raised floor areas, balconies and porches shall have intermediate rails or ornamental closures that do not allow passage of a sphere 4 inches in diameter. Exceptions: Openings for required guards on the sides of stair treads shall not allow a sphere 4 3/8 inches to pass through.

Required guards shall not be constructed with horizontal rails or other ornamental pattern that results in a ladder effect.

HANDRAILS:

Handrails must be graspable, returned and at least on one side.

STEPS:

Rise and height cannot vary more than 3/8" of each other.

UNDERPINNING

Underpinning must be installed with approved materials for this purpose. Metal, vinyl, masonry (brick, block, stone) or treated wood .Please leave one piece of underpinning off at the middle and ends of the home for inspection.

REMOVAL OF DEBRIS

The under-floor grade shall be cleaned of all vegetation and organic material. All wood forms used for placing concrete shall be removed before a building is occupied or used for any purpose. All construction materials shall be removed before a building is occupied or used for any purpose.